

NOTES:

1. SEWER LATERALS SHALL HAVE A MINIMUM SLOPE OF 2%, UNLESS APPROVED OTHERWISE BY THE CITY ENGINEER.

2. LATERAL SHALL BE CUT BACK TO SOUND MATERIAL FOR COUPLING.

3. ALL CONNECTIONS TO THE CITY SEWER MAINS MUST BE CORE DRILLED.

4. ENCASE LATERAL CONNECTION IN CEMENT, STABILIZED SAND OR 2000 PSI CONCRETE FOLLOWING INSTALLATION. CONNECTION MUST BE INSPECTED BY CITY PRIOR TO BACKFILL.

5. NO LATERAL CONNECTIONS SHALL BE MADE TO SANITARY SEWER "INTERCEPTOR" LINES WITHOUT THE APPROVAL OF THE CITY ENGINEER.

6. ALL APPLICABLE SANITARY SEWER PIPE INSTALLATION WORK SHALL BE IN ACCORDANCE WITH THE UNIFORM PLUMBING CODE.

7. THE LOCATION OF EACH LATERAL SHALL BE PERMANENTLY IDENTIFIED BY STAMPING AN "S" IN THE TOP OF THE CURB AT THE LOCATION WHERE THE LATERAL CROSSES THE CURB LINE.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION RENO	
			NOTES—LATERAL DETAIL	DRAWING NO. R-224B (306)	
				DATE 01/04 PAGE 230	
APPROVED BY: G.S. 01/04					